

The Embedded I/O Company



TA309

Cable Kit for Modules with Pico-Clasp Connector

Version 1.0

User Manual

Issue 1.0.0

May 2016

TEWS TECHNOLOGIES GmbH

Am Bahnhof 7 25469 Halstenbek, Germany

Phone: +49 (0) 4101 4058 0 Fax: +49 (0) 4101 4058 19

e-mail: info@tews.com www.tews.com

TA309-10R

Cable Kit for Modules with Pico-Clasp Connector

This document contains information, which is proprietary to TEWS TECHNOLOGIES GmbH. Any reproduction without written permission is forbidden.

TEWS TECHNOLOGIES GmbH has made any effort to ensure that this manual is accurate and complete. However TEWS TECHNOLOGIES GmbH reserves the right to change the product described in this document at any time without notice.

TEWS TECHNOLOGIES GmbH is not liable for any damage arising out of the application or use of the device described herein.

Style Conventions

Hexadecimal characters are specified with prefix 0x, i.e. 0x029E (that means hexadecimal value 029E).

For signals on hardware products, an ‚Active Low’ is represented by the signal name with # following, i.e. IP_RESET#.

Access terms are described as:

W	Write Only
R	Read Only
R/W	Read/Write
R/C	Read/Clear
R/S	Read/Set

©2016 by TEWS TECHNOLOGIES GmbH

All trademarks mentioned are property of their respective owners.

Issue	Description	Date
1.0.0	Initial Issue	May 2016

Table of Contents

1	PRODUCT DESCRIPTION	5
2	CABLE PIN ASSIGNMENT	6
3	TERMINAL BLOCK PIN ASSIGNMENT.....	7
4	ASSEMBLY DRAWING	8

List of Figures

FIGURE 4-1 : TERMINAL BLOCK ASSEMBLY DRAWING	8
FIGURE 4-2 : CABLE ASSEMBLY DRAWING	8

List of Tables

TABLE 2-1 : CABLE PIN ASSIGNMENT	6
TABLE 3-1 : TERMINAL BLOCK PIN ASSIGNMENT	7
TABLE 3-2 : TERMINAL BLOCK ADDITIONAL TERMINAL PIN ASSIGNMENT	7

1 Product Description

The TA309 cable kit combines the TA205 Pico-Clasp Terminal Block and the TA111 Pico-Clasp cable. It is used as a standard interface to connect TEWS modules with Pico-Clasp connector to other system devices. The TA309 Cable Kit is therefore an essential wiring interface for prototyping and in the same way for machines and peripheral equipment.


Always two wires of the 30 pin Pico-Clasp cable are constructed as twisted pairs (1 and 2, 3 and 4, ..., 29 and 30).

The cable length is 0.5 m and the permissible maximum voltage for the TA309 is 50V DC.

The Pico-Clasp Terminal Block has a universal socket and may simply mount on standard EM mounting rails as a compact terminal strip. Screw connections of the used terminal block have a nominal cross section of 2.5 mm².

An additional screw connector provides a possibility to connect i.e. a cable shield with an external case ground.

2 Cable Pin Assignment

The Pico-Clasp cable provides a one to one connection between the Pico-Clasp connectors P1 and P2. The “” symbol denotes the wires that are constructed as twisted pairs.
















Pico-Clasp P1	Pico-Clasp P2		Pico-Clasp P1	Pico-Clasp P2
1	1		2	2
3	3		4	4
5	5		6	6
7	7		8	8
9	9		10	10
11	11		12	12
13	13		14	14
15	15		16	16
17	17		18	18
19	19		20	20
21	21		22	22
23	23		24	24
25	25		26	26
27	27		28	28
29	29		30	30

Table 2-1 : Cable Pin Assignment

3 Terminal Block Pin Assignment

Pico-Clasp	Terminal Block	Pico-Clasp	Terminal Block
1	1	16	16
2	2	17	17
3	3	18	18
4	4	19	19
5	5	20	20
6	6	21	21
7	7	22	22
8	8	23	23
9	9	24	24
10	10	25	25
11	11	26	26
12	12	27	27
13	13	28	28
14	14	29	29
15	15	30	30

Table 3-1 : Terminal Block Pin Assignment

The additional screw terminal block is not connected to any pins of the Pico-Clasp connector. It can be used to connect an external cable shield to the case ground.

Terminal	Descr.
1	e.g. Shield or Case Ground
2	

Table 3-2 : Terminal Block Additional Terminal Pin Assignment

4 Assembly Drawing




Figure 4-1 : Terminal Block Assembly Drawing




Figure 4-2 : Cable Assembly Drawing